



### Technical Query Sheet

Section/Work Site		Utilities Section 1B Plates 22 - 26	
Technical Query No: MUDFA 223		Date Raised: 08/08/08	
Raised By: Graeme Walker		Position: CDM Co-ordinator	
General Description of Query: Review of Health & Safety Residual Risk Register			
<u>Health &amp; Safety Residual Risk Register</u>			
<p>No reference is included to the hazard of the location of cellars, basements, other voids and underground obstructions that was included within the RRR for utility works in this area. (UTL-11 on ULE90130-01-RRR-00012).</p> <p>Does this mean that it has been confirmed that the hazard does not exist, or should the item be included?</p>			
Issued to: A Dolan Organisation: SDS		Target Date for Response: 15/8/08	
Copied to/Organisation:			
Query Answer:			
<p>The hazard has been identified within DRA: ULE90130-01-DRA-00022 it was determined that the risk posed by the aforementioned hazard was reduced to a level whereby it was deemed that it need not be carried forward to the RRR. In addition the location of the works were assessed and the locations found to be of adequate distances from building line as to be minimal risk for sewer manhole works, as apposed to the normal utility works. Should you wish to instruct us to change the level of risk in order that it becomes a notifiable RRR, then please feel free to do so.</p>			
Approved by: Chris Row		Organisation: (Harrow) SDS	
Signed: [Redacted]		Date: 15/8/08	
Query Closed by tie - Give Details: [Redacted]		18/8/08	
Closed By: Graeme Walker		Signed: [Redacted]	
		Date: 25/08/08	

DOC.NO. DEL.MUDFA.9901	ISSUE	TITLE: MUDFA TQ 223	SHEET 1
---------------------------	-------	------------------------	------------